


Bio Energy with CCS (BECCS): Large potential for BioSNG at low CO₂ avoidance cost

Michiel C. Carbo
Ruben Smit
Bram van der Drift
Daniel Jansen

Presented at the 10th International Conference on Greenhouse Gas Technologies (GHGT-10), 19 – 23 September 2010, Amsterdam, The Netherlands

ECN-M--10-098 DECEMBER 2010





ECN

Energy research Centre of the Netherlands

"ECN develops highlevel knowledge and technologies for a sustainable energy system and transfers those to the market"



Energy research Centre of the Netherlands

www.ecn.nl

ECN-M--10-098 3



ECN in brief

- ECN is the largest, independent, market oriented and innovative Dutch energy research institute
- 84 M€/a turnover (2008)
- 690 employees (~630 fte)
- 500 scientific publications/reports each year;
 10-15 international patents each year
- (Inter)national co-operation with companies, universities and research institutes

3

Energy research Centre of the Netherlands

www.ecn.nl




Bio Energy with CCS (BECCS)

- Conversion of biomass to electricity/heat/fuels/ products combined with CO₂ capture and storage
- BECCS potentially leads to negative CO₂ emissions, i.e. CO₂ uptake from the atmosphere through natural sequestration of CO₂ in biomass
- Offset of both historical and distributed CO₂ emissions
- BECCS is indispensable to cost-effectively achieve most stringent global warming stabilisation scenarios
- Fossil fuel fired power plants with CCS ultimately only mitigate 80-90% of current CO₂ emissions

Energy research Centre of the Netherlands

www.ecn.nl





BECCS research at ECN

- BECCS research is multidisciplinary collaboration between different units:
 - Biomass, Coal & Environmental research
 - Hydrogen & Clean Fossil Fuels
 - Policy Studies
- · Research topics:
 - Mapping sources & sinks, LCA, public perception
 - Policy measures & incentives
 - Assessment conversion routes

Energy research Centre of the Netherlands

www.ecn.nl

ECN-M--10-098 5



BioSNG

Natural gas in the Netherlands:


- 45% of primary energy consumption
- 135,000 km transportation grid
- 94% of all households connected


BioSNG:


- Ease of making distributed conversion more sustainable
- Possibility to decouple production and consumption
- Net CO₂ uptake from atmosphere possible through CCS

Energy research Centre of the Netherlands

www.ecn.nl







ECN-M--10-098 7



Current status BioSNG

- Güssing (Austria): 1 MW_{SNG} pilot plant (existing)
- GoBiGas (Götenburg, Sweden) commercial plant: 20 MW_{SNG} (2012) & 80 MW_{SNG} (2016)
- HVC & ECN (The Netherlands) commercial plant: 4 MW_{CHP} (2012) & 35 MW_{SNG} (2015)

All based on indirect biomass gasification:

- Carbon conversion 100%
- N₂-lean product gas
- High initial CH₄ content

11


Energy research Centre of the Netherlands

www.ecn.nl



MILENA Indirect Gasifier

- Two integrated reactors for gasification and combustion
- Essentially N₂-free producer gas
- Complete conversion
- High methane yield, tailored for SNG-production







IILEINA, 160 Kg/n, 2008

MILENA principle


Energy research Centre of the Netherlands


2004

www.ecn.nl











Assumptions (1)

- Plant size ~500 MW_{th} input
- Plant simulated using AspenPlus V7.1
- Costing:
 - Early 2010
 - Greenfields, overnight
 - Nth plant, North-western Europe

17

Energy research Centre of the Netherlands

www.ecn.nl



Assumptions (2)

· Gasification pressure: 7 bara

• TCI: 1,100 €/kW_{SNG}

O&M: 5% of TCI

• Other ficed cost: 2% of TCI

• Return on Investment: 12%

• Interest: 5%

Biomass price (dry): 4 €/GJ

• Electricity price: 0.05 €/kWh (14 €/GJ)


CO₂ emission natural gas combustion: 55 kg/GJ

18

Energy research Centre of the Netherlands

www.ecn.nl

ECN Economic analysis (1)		
TCI	55.2	3.50
Biomass	89.7	5.69
Electricity	10.9	0.69
O&M	28.6	1.82
Other fixed cost	11.4	0.73
Total cost	195.8	12.42
Result	13.5	0.86
	209.4	13.28





Conclusions

- Incremental cost for CO₂ capture and storage is low;
 CO₂ separation equipment implemented regardless of application CCS
- · Retrofit application of CCS is straightforward
- CO₂ avoidance costs for BioSNG competitive with CCS in fossil fired power plants
- Accounting for net CO₂ uptake from atmosphere lowers avoidance costs and accelerates deployment
- Scale-up indirect gasification technology needed

2

Energy research Centre of the Netherlands

www.ecn.nl



Questions

More information: Michiel C. Carbo

e: carbo@ecn.nl P.O. Box 1

t: +31 224 56 4792 NL-1755 ZG Petten w: www.ecn.nl the Netherlands

Publications: www.ecn.nl/publications
Fuel composition database: www.phyllis.nl
Tar dew point calculator: www.thersites.nl
IEA bioenergy/gasification: www.eatask33.org
Milena indirect gasifier: www.milenatechnology.com
OLGA tar removal: www.olgatechnology.com
SNG: www.bioCNG.com

Energy research Centre of the Netherlands

www.ecn.nl